

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0533:104

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Viking, 210 N. Industrial Park Rd., Hastings MI 49058
Contact: Eldon Jackson (269) 945-9501 FAX (269) 945-9599

DESIGN: Model C, Part Nos. 11723, -24, -25, -26, -27, -28, -29, and -30, normally closed, rate compensation type heat detectors. Models are suitable for releasing device service in light and ordinary hazard fire sprinkler systems. Refer to listee's data sheet for detailed product descriptions and operational considerations.

RATING: 140 - 225°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units with Vikings' fire sprinkler system as releasing device.

XLf: 7270-0074:104

03-18-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 18, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**